



EXCAVATION

6FT x 6FT HOLE

FROM BOTTOM OF  
TANK TO BOTTOM OF:  
INLET PIPE - 55'  
OUTLET PIPE - 52'

TANK SPECIFICATION

- TOP AND BOTTOM - 4 INCHES THICK
- SIDE WALL - 3 INCHES THICK
- ACCESS LID - 24 INCH LID LOCATED IN CENTER OF TANK
- 630 GAL. - SEPTIC TANK CAPACITY 13 1/8 GAL/IN
- 670 GAL. - DOSING TANK CAPACITY 13 1/8 GAL/IN

**PARSONS**  
**INC.**

658 HANOVER-KENDALL RD.  
HOOKSTOWN, PA. 15050

(724) 899-2933 FAX: (724) 899-3532

600 GALLON  
CONCRETE TANK

NOTE: PRODUCT IS CONSTRUCTED OF VIBRATED	DATE: 06/15/00	SCALE: NTS
FULLY REINFORCED CONCRETE, USING A 6 1/2	DRAWN BY: <b>DAVID E. WERTZ</b>	
BAG/YD. OF HIGH EARLY CEMENT.		